



PV1320 - Cell data sheet

Classification

Brand	Alcad
Cell type	PV1320
Cell P/N	31-10034-8*
Capacity at 5 hours rate	1 220 Ah
IEC Designation	KGL 1220 P
According to IEC 62259	



Physical data

Overall height	405 mm	Weight per cell	51,3 Kg
Width	195 mm	Block length - 2 cells	
Length	387 mm	Block length - 4 cells	
Block length - 3 cells		Block length - 6 cells	
Block length - 5 cells		Block length - 8 cells	
Block length - 7 cells		Block length - 10 cells	
Block length - 9 cells			

Construction

Container material	Polypropylene	No. of terminals/polarity	5
Separator type	Felt	Terminal material	Steel
Connection torque	30,0 +/- 3,0 Nm	Vent type	flame arresting vent (large)
Terminal size	M10		

Plates

Positive		Negative	
Type of plates	Ultra Low Maintenance Pocket	Type of plates	Ultra Low Maintenance Pocket

ALCAD confidential and proprietary. The data herein given are for information purposes only and are not binding on ALCAD. They may be modified without prior notice. Please contact an ALCAD representative in order to obtain confirmation of the above data.

Visit our website at www.alcad.com

Version: 1.5, Last updated on 04/2015

P 1/2



PV1320 - Cell data sheet

Electrolyte

Electrolyte type: Renewal	E13	Max/Min	50 mm
Electrolyte type: Initial	E29	Vent oil quantity	
Electrolyte per cell: Liquid	12,7 liters		

Connection

Cable area	70 mm ²
------------	--------------------

Charging

Float voltage	1,42 V/Cell	High rate voltage (min)	1,45 V/Cell
Single-level voltage	1,42 V/Cell		

Resistance/Short circuit

Internal resistance	0,20 mOhm	Short circuit current	7389 A
---------------------	-----------	-----------------------	--------

Performance data

Photovoltaic performance

For a fully charged cell after a constant current charge according to IEC 62259 standard at +20°C +/- 5°C (+68°F +/- 9°F)

V/Cell	1h
1	1 718

ALCAD confidential and proprietary. The data herein given are for information purposes only and are not binding on ALCAD. They may be modified without prior notice. Please contact an ALCAD representative in order to obtain confirmation of the above data.

Visit our website at www.alcad.com

Version: 1.5, Last updated on 04/2015

P 2/2